

DISCOM : BRPL
OUTAGE REPORT FOR : 05/08/2018 06:00Hr. To 06/08/2018 06:00Hr.

Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Area / DT Effected	No. of consumer affected	Remarks
						Main Reason	Detail				
1	05/08/2018	NHP	06:04	07:10	01:05	HT SYSTEM FAULT	Grid:V.S.N.L (33/11kV) GRID SSTN To Feeder:11kV FDR R-BLOCK G.K-1 , 11kV GRID PANEL,:PROTECTION MALFUNCTION,	RESTORED/ REPAIRED	Part of : ,GREATER KAILASH I BLOCK R,G K ENCLAVE I,HEMKUNT COLONY	354	
2	05/08/2018	VKP	06:43	08:03	01:20	HT SYSTEM FAULT	Grid:HASTAL (66/11kV) GRID SSTN To Feeder:11kV FDR VIKAS KUNJ SCHOOL WALA , TRANSIENT FAULT,:TRANSIENT FAULT,	RESTORED/ REPAIRED	Part of : ,VIKAS NAGAR,VUJAY VIHAR,DEEPAK VIHAR_2	678	
3	05/08/2018	KPR	07:25	08:55	01:30	HVDS CABLE & OTHER SYSTEM	Grid:TUOHLAKABAD (33/11kV) GRID SSTN To Feeder:11kV FDR G-2 K-19 SANGAM VIHAR , HVDS,:HVDS DP FUSE BLOWN,	RESTORED/ REPAIRED	Part of : ,SANGAM VIHAR BLOCK H,SANGAM VIHAR BLOCK G-2,SANGAM VIHAR BLOCK K,TALIMABAD,SANGAM VIHAR BLOCK G	685	
4	05/08/2018	TGN	09:57	11:05	01:08	HT SYSTEM FAULT	Grid:MUHERJEE PARK (33/11kV) GRID SSTN To Feeder:11kV FDR IND. AREA TILAK NAGAR , HT O/H,:BIRDAGE,	RESTORED/ REPAIRED	Part of : TILAK NAGAR BLOCK 8,,GANGARAM VATIKA_2,TILAK NAGAR BLOCK 5A_2,TILAK NAGAR BLOCK 4A_2,TILAK NAGAR	412	
5	05/08/2018	SVR	10:20	11:21	01:01	LT FEEDER	Grid:SARITA VIHAR (66/11kV) GRID SSTN To Feeder:11kV FDR N-BLOCK ABUL FAZAL ENCLAVE , SERVICE LINE,:SERVICE LINE LOOSE FROM POLE,	RESTORED/ REPAIRED	Part of : DAWAT NAGAR	72	
6	05/08/2018	KPR	10:31	12:27	01:55	HVDS CABLE & OTHER SYSTEM	Grid:TUOHLAKABAD (33/11kV) GRID SSTN To Feeder:11kV FDR G-2 K-19 SANGAM VIHAR , HVDS,:FIRE ON THE POLE,	RESTORED/ REPAIRED	Part of : SANGAM VIHAR BLOCK H,SANGAM VIHAR BLOCK G-2,SANGAM VIHAR BLOCK K,TALIMABAD,SANGAM VIHAR BLOCK G	732	
7	05/08/2018	NGL	11:15	15:10	03:55	PLANNED SHUTDOWN	Grid:UDYOG NAGAR (33/11kV) GRID SSTN To Feeder:11kV FDR O/G S/STN:NO-1 UDYOG NGR , LT CIRCUIT:REPLACEMENT OF LT ACB	RESTORED/ REPAIRED	Part of : UDYOG NAGAR_2,	67	
8	05/08/2018	NGL	11:15	15:10	03:55	PLANNED SHUTDOWN	Grid:UDYOG NAGAR (33/11kV) GRID SSTN To Feeder:11kV FDR UDYOG NGR.NO-4 (NEW) , LT CIRCUIT:TO ATTEND FAULT IN CIRCUIT	RESTORED/ REPAIRED	Part of : UDYOG NAGAR_2,	69	
9	05/08/2018	NGL	11:15	15:09	03:54	PLANNED SHUTDOWN	Grid:UDYOG NAGAR (33/11kV) GRID SSTN To Feeder:11kV FDR O/G S/STN NO-2 UDYOG NAGAR SSTN-2 , LT CIRCUIT:TO ATTEND FAULT IN CIRCUIT	RESTORED/ REPAIRED	Part of : UDYOG NAGAR_2,	64	
10	05/08/2018	SVR	11:59	13:05	01:05	HT SYSTEM FAULT	Grid:SARITA VIHAR (66/11kV) GRID SSTN To Feeder:11kV FDR N-BLOCK ABUL FAZAL ENCLAVE , 11kV CABLE,:CABLE FAULT,	RESTORED/ REPAIRED	Part of : ABDUL FAZAL ENCLAVE,,CANAL COLONY,ABDUL FAZAL ENCLAVE PART I_1,DAWAT NAGAR	647	
11	05/08/2018	SVR	13:47	16:06	02:18	PLANNED SHUTDOWN	Grid:MATHURA ROAD (66/11kV) GRID SSTN To Feeder:11kV FDR S/S. NO.-3 MCIE B-1 BLOCKKHAN BABA NAGAR FDR.-3 , LT ACB:MAINTENANCE	RESTORED/ REPAIRED	Part of : MOHAN COOPERATIVE INDUSTRIAL ESTATE_2,	2	
12	05/08/2018	SVR	13:55	16:07	02:11	PLANNED SHUTDOWN	Grid:MATHURA ROAD (66/11kV) GRID SSTN To Feeder:11kV FDR S/S. NO.-3 MCIE B-1 BLOCKKHAN BABA NAGAR FDR.-3 , RMU/RMU REPLACEMENT	RESTORED/ REPAIRED	Part of : B-1/E-27 MCIE	1	
13	05/08/2018	TGN	14:40	15:56	01:15	HT SYSTEM FAULT	Grid:CHAUKHANDI (33/11kV) GRID SSTN To Feeder:11kV FDR 224-SFS QTS , HT O/H,:TREE TOUCHING,	RESTORED/ REPAIRED	Part of : SAHIB PURA,MAJOR BHUPENDER SINGH NAGAR,SAHPURA_1	612	
14	05/08/2018	PLM	17:17	18:22	01:05	HT SYSTEM FAULT	Grid:PAPPANKALAN-I (220/66/11kV, TRANSCO) GRID SSTN To Feeder:11kV FDR NASIRPUR , TRANSIENT FAULT,:TRANSIENT FAULT,	RESTORED/ REPAIRED	Part of : SECTOR 1,,HARIJAN BASTI SECTOR 1,MANGLA PURI PART II,MANGLA PURI_2,DWARKA SECTOR 1,MAHAVIR ENCLAVE PART	462	
15	05/08/2018	MDK	17:35	18:43	01:07	HT SYSTEM FAULT	Grid:NANGLOI WATER WORKS (66/11kV) GRID SSTN To Feeder:11kV FDR RAJDHANI PARK , HT O/H,:JUMPER BROKEN,	RESTORED/ REPAIRED	Part of : MUNDKA VILLAGE_2,,AMAR COLONY_2	524	
16	05/08/2018	MNG	18:33	19:50	01:16	HT SYSTEM FAULT	Grid:MATYALA (G-5 PPK) (66/11kV) GRID SSTN To Feeder:11kV FDR SEWAK PARK VIKAS PURI , TRANSIENT FAULT,:TRANSIENT FAULT,	RESTORED/ REPAIRED	Part of : MANSA RAM PARK_3,SHANTI PARK,	704	
17	05/08/2018	DWK	21:43	23:15	01:32	HT SYSTEM FAULT	Grid:PAPPANKALAN-I (220/66/11kV, TRANSCO) GRID SSTN To Feeder:11kV FDR MAHALAXMI , TRANSIENT FAULT,:TRANSIENT FAULT,	RESTORED/ REPAIRED	Part of : DWARKA SECTOR 6,	418	
18	05/08/2018	JKP	21:55	23:02	01:06	HT SYSTEM FAULT	Grid:MAYAPURI (33/11kV) GRID SSTN To Feeder:11kV FDR MAHARANI , 11kV CABLE,:CABLE FAULT,	RESTORED/ REPAIRED	Part of : MAYAPURI INDUSTRIAL AREA PHASE II_1,BLOCK E MAYAPURI INDUSTRIAL AREA PHASE II,ZAMRUDPUR,BLOCK C	458	
19	05/08/2018	MNG	22:03	23:08	01:04	HT SYSTEM FAULT	Grid:PAPPANKALAN-II (220/66/11kV, TRANSCO) GRID SSTN To Feeder:11kV FDR DMRC SHOPPING COMPLEX , TRANSIENT FAULT,:TRANSIENT FAULT,	RESTORED/ REPAIRED	Part of : MANSA RAM PARK_3,SHANTI PARK,,RAMA PARK,DWARKA SECTOR 14,MOHAN GARDEN BLOCK B	724	
20	05/08/2018	MDK	23:29	00:45	01:16	HT SYSTEM FAULT	Grid:NANGLOI (66/33/11kV) GRID SSTN To Feeder:11kV FDR MUNDKA , HT O/H,:JUMPER BROKEN,	RESTORED/ REPAIRED	Part of : ,NANGLOI EXTN.,AMAR COLONY_2,MUNDKA VILLAGE_2	612	
21	06/08/2018	DWK	02:26	03:55	01:28	DISTRIBUTION TR.	Grid:G-15 DWARKA REL. ENERGY GRID SSTN To Feeder:11kV FDR DJA APPT , HT CONSUMER,:CONSUMER TRANSFORMER FAULTY,	RESTORED/ REPAIRED	Part of : DWARKA SECTOR 13,AYUDH VIHAR,DWARKA SECTOR 13 PKT 1,DWARKA SECTOR 13 PHASE II,DWARKA SECTOR 13 PHASE I	541	
22	06/08/2018	MDK	04:23	06:08	01:44	HT SYSTEM FAULT	Grid:NANGLOI (66/33/11kV) GRID SSTN To Feeder:11kV FDR MUNDKA , HT O/H,:JUMPER BROKEN,	RESTORED/ REPAIRED	Part of : ,NANGLOI EXTN.,AMAR COLONY_2,MUNDKA VILLAGE_2	568	