

OUTAGE REPORT FOR : 16/10/2018 06:00Hr. To 17/10/2018 06:00Hr.

Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Area / DT Effected	No. of consumer affected	Remarks
						Main Reason	Detail				
1	16/10/2018	SVR	19:48	21:21	01:33	HT SYSTEM FAULT	Grid:MOHAN CO-OPERATIVE (66/11kV) GRID SSTN To Feeder:11kV FDR O/G LAV KUSH D.P , TRANSIENT FAULT, TRANSIENT FAULT.	RESTORED/ REPAIRED	Part of : PER BABA BASTI JAITPUR,, ARPAN VIHAR,, LUV KUSH CHOW	496	
2	16/10/2018	TGN	17:44	19:26	01:41	HT SYSTEM FAULT	Grid:MUHMERJE PARK (33/11kV) GRID SSTN To Feeder:11kV FDR B-BLOCK J.J COLONEY CHAUKHANDI , DISTRIBUTION TRANSFORMER TRANSFORMER FUSE BLOWN.	RESTORED/ REPAIRED	Part of : CHAUKHANDI,, RAVI NAGAR,, VISHNU GARDEN	508	
3	16/10/2018	SVR	16:55	18:17	01:22	HT SYSTEM FAULT	Grid:MATHURA ROAD (66/11kV) GRID SSTN To Feeder:11kV FDR O/G S/S NO-1 M.C.I.E , 11kV CABLE CABLE FAULT.	RESTORED/ REPAIRED	Part of : MOHAN CO-OPERATIVE INDUSTRIAL AREA	327	
4	16/10/2018	NHP	15:55	17:17	01:22	HT SYSTEM FAULT	Grid:NEHRU PLACE (33/11kV) GRID SSTN To Feeder:11kV FDR O/G TO DELHI ADMIN. FLATS , 11kV CABLE CABLE FAULT.	RESTORED/ REPAIRED	Part of : DELHI ADMIN FLATS,, KAILASH KUNI,, KAILASH COLONEY	428	
5	16/10/2018	MDK	12:19	13:37	01:17	HT SYSTEM FAULT	Grid:NANGLOI WATER WORKS (66/11kV) GRID SSTN To Feeder:11kV FDR VARDHMAN VATIKA , LT CBL BURNAGE	RESTORED/ REPAIRED	Part of : SWARN PARK,, MUNDIKA EXTN., MUNDKA VILLAGE	516	
6	16/10/2018	MNG	10:46	12:12	01:26	HT SYSTEM FAULT	Grid:MATHALA (G-S PPK) (66/11kV) GRID SSTN To Feeder:11kV FDR CBD BLOCK MOHAN GARDEN , TRANSIENT FAULT, TRANSIENT FAULT.	RESTORED/ REPAIRED	Part of : MOHAN GARDEN	489	
7	16/10/2018	MNG	10:46	12:28	01:42	HT SYSTEM FAULT	Grid:HASTAL (66/11kV) GRID SSTN To Feeder:11kV FDR JHANDA CHOW OM VIHAR , RMU 2M/LT PANEL FLASH	RESTORED/ REPAIRED	Part of : ZAILDAR ENCLAVE NAWADA,, MAIRA VILLAGE NAWADA , OM VIHAR HASTAL	480	
8	16/10/2018	JFR	20:37	22:07	01:29	LT FEEDER	Grid:JAFFARPUR (66/11kV) GRID SSTN To Feeder:11kV FDR KHERA DABAR , DISTRIBUTION TRANSFORMER TRANSFORMER RUBINT.	RESTORED/ REPAIRED	Part of : VILLAGE SUREHRA	59	
9	16/10/2018	MNG	10:51	12:28	01:37	LT FEEDER	Grid:HASTAL (66/11kV) GRID SSTN To Feeder:11kV FDR OM VIHAR PHASE-2 , DISTRIBUTION TRANSFORMER TRANSFORMER FUSE BLOWN.	RESTORED/ REPAIRED	Part of : OM VIHAR PH-3	51	
10	16/10/2018	PLM	13:20	16:42	03:22	PLANNED SHUTDOWN	Grid:66 kV G - 2 P.P.X (NASEERPUR) GRID To Feeder:11kV FDR KAILASH PURI NO-1 , 11kV FEEDER CARRY OUT PREVENTIVE MTC	RESTORED/ REPAIRED	Part of : INDRA PH. , KAILASHPURI ZONAL OFFICE,, SADH NAGAR GALI NO-14 16&17 , KAILASHPURI MAIN , DDA PARK BAL NAGAR.	498	
11	16/10/2018	SVR	12:10	14:14	02:04	PLANNED SHUTDOWN	Grid:33 kV JAMIA MILLIA GRID To Feeder:11kV FDR O/G FILTERATION PLANT , 11kV FEEDER REPAIR OF RMU	RESTORED/ REPAIRED	Part of : SATAFF QUATER JAMIA,, OKHLA FILTERATION PLANT (HT CONSUMER), SHAHEEN BAGH, B BLOCK FRIENDS COLONY.	511	
12	16/10/2018	TGN	12:10	16:35	04:25	PLANNED SHUTDOWN	Grid:66 kV BODELLA - 2 GRID To Feeder:11kV FDR MBS NAGAR , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : M.B.S NAGAR,, TILAK NAGAR,, SANT GARH,, HIND NAGAR,, NUKHREKE PARK,, VISHNU GARDEN	493	
13	16/10/2018	KPR	12:00	16:36	04:36	PLANNED SHUTDOWN	Grid:33 kV TUGHAKABAD GRID To Feeder:11kV FDR G & H BLOCK SVNHAR , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : G & H BLOCK SANGAM VIHAR,, BUDHA PARK MADANGIR	517	
14	16/10/2018	PLM	11:50	14:30	02:40	PLANNED SHUTDOWN	Grid:66 kV G - 2 P.P.X (NASEERPUR) GRID To Feeder:11kV FDR PURAN JAILDAR , TRANSFORMER-CIVIL WORK	RESTORED/ REPAIRED	Part of : ABC-BLOCK MAHAVEER ENCLAVE	464	
15	16/10/2018	JFR	11:40	16:48	05:08	PLANNED SHUTDOWN	Grid:66 kV JAFFARPUR GRID To Feeder:11kV FDR KHERA DABAR , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : KHERA DABAR VILLAGE,, UJAWA VILLAGE,, RAM CHANDER VILL KATPUR,, JAFFARPUR EXTENSION, VILLAGE	469	
16	16/10/2018	PLM	11:20	14:46	03:26	PLANNED SHUTDOWN	Grid:66 kV G - 2 P.P.X (NASEERPUR) GRID To Feeder:11kV FDR DWARKA PURI , 11kV FEEDER CARRY OUT PREVENTIVE MTC	RESTORED/ REPAIRED	Part of : BARAAT GHAR,, TAMIL ENCL., DABRI MORE,, DWARKA PURI	471	
17	16/10/2018	NZD	11:10	15:27	04:17	PLANNED SHUTDOWN	Grid:220kV LOOH ROAD TRANSO GRID To Feeder:11kV FDR N.B.C.C EAST BLOCK , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : N.B.C.C EAST TOWER (HT CONSUMER), PRAGATI VIHAR, C-BLOCK LAIPAT NAGAR	458	
18	16/10/2018	PLM	11:00	14:45	03:45	PLANNED SHUTDOWN	Grid:G-7 DWARKA GRID To Feeder:11kV FDR SSTN NO.-2 SECTOR-7 (PLM), 11kV FEEDER CARRY OUT PREVENTIVE MTC	RESTORED/ REPAIRED	Part of : HAPPY HOME (HT CONSUMER), LOCAL SHOPPING CENTRE SEC-7 (HT CONSUMER), SRIGANESHI HT CONSUMER)	519	
19	16/10/2018	MDK	11:00	15:46	04:46	PLANNED SHUTDOWN	Grid:66 kV NANGLOI GRID To Feeder:11kV FDR BAKKARWALA VILLAGE , 11kV FEEDER: TREE TRIMMING	RESTORED/ REPAIRED	Part of : YADAV PARK,, GULSHAN PARK,, RAJDHANI PARK,, POLICE OTS NANGLOI, VEFNA ENCLAVE, MUNDKA VILLAGE.	520	
20	16/10/2018	UMN	11:00	14:53	03:53	PLANNED SHUTDOWN	Grid:66 kV G - 3 P.P.X (BINDAPUR) GRID To Feeder:11kV FDR CHANAKYA PLACE I/O SSTN NO-1 , LT CIRCUIT MAINTANCE WORK	RESTORED/ REPAIRED	Part of : BINDAPUR	68	
21	16/10/2018	SVR	11:00	15:16	04:16	PLANNED SHUTDOWN	Grid:220kV SANITA VHR TRANSO GRID To Feeder:11kV FDR ALI VILLAGE , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : GAUTAMPURI, ALI VILLAGE , ALI EXTN.	518	
22	16/10/2018	HKS	11:00	15:54	04:54	PLANNED SHUTDOWN	Grid:33 kV ADCHIN GRID To Feeder:11kV FDR BHIM NAGRI (L.T/S/S NO-2 , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : BHIM NAGRI,, KATWARIA SARAI,, SWAMI NAGAR	507	
23	16/10/2018	PJB	11:00	14:15	03:15	PLANNED SHUTDOWN	Grid:33 kV S.B.MILL GRID To Feeder:11kV FDR J.J CLUSTER SHIVA NANO SCHOOL , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : MADAN PARK EAST PUNJABI BAGH,, WEST PUNJABI BAGH,, MARKET EAST PUNJABI BAGH	151	
24	16/10/2018	VKI	11:00	13:43	02:43	PLANNED SHUTDOWN	Grid:220kV VASANT KUNI TRANSO GR To Feeder:11kV FDR NAGA DAIRY , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : BLOCK E MAHIPALPUR VILLAGE	489	
25	16/10/2018	NGL	11:00	14:52	03:52	PLANNED SHUTDOWN	Grid:66 kV PASCHIM VIHAR GRID To Feeder:11kV FDR NILOTHI STP , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : TAK CHAND COLONY,, NILOTHI VILLAGE,, DEEPAK VIHAR,, SHIV RAM PARK NILOTHI MORE	499	
26	16/10/2018	JKP	11:00	15:30	04:30	PLANNED SHUTDOWN	Grid:33 kV MAYAPURI GRID To Feeder:11kV FDR THAR JAIL , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : THAR JAIL (HT CONSUMER) JANAKPURI,, A/C-BLOCK POSANGIPUR JKP	1	
27	16/10/2018	JFR	11:00	16:47	05:47	PLANNED SHUTDOWN	Grid:66 kV JAFFARPUR GRID To Feeder:11kV FDR NAVEEN PLACE , 11kV FEEDER MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : JANTA VIHAR JHARODA ROAD,, PAHWAA FARM ANAJ MANDI , NAVEEN PLACE VINOBHIA ENCLAVE, SAINIK ENCLAVE	496	
28	16/10/2018	SVR	11:00	15:17	04:17	PLANNED SHUTDOWN	Grid:66 kV M.C.I.E GRID To Feeder:11kV FDR DP SKS , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : SAREZ MANDI MULAR BANOH EXTN., HARI NGR EXT., TAJPUR PAHARI BHARAT GHAR,, KHADDA COLONY JAITEPUR	511	
29	16/10/2018	VKI	11:00	16:09	05:09	PLANNED SHUTDOWN	Grid:33 kV ANDHERIA BAGH GRID To Feeder:11kV FDR O/G TO GHITORANI , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : GHITORNI VILLAGE, SEC-C POCKET-9 VASANT KUNI	509	
30	16/10/2018	JKP	10:59	15:31	04:32	PLANNED SHUTDOWN	Grid:66 kV HARI NAGAR GRID To Feeder:11kV FDR FATEH NAGAR , LT CIRCUIT-MAINTANCE WORK	RESTORED/ REPAIRED	Part of : FATEH NAGAR,, RAJOURI GARDEN	64	
31	16/10/2018	JKP	10:59	12:10	01:11	PLANNED SHUTDOWN	Grid:REWARI LINE GRID (NDPL) To Feeder:11kV GOVERNMENT PRESS , RMU/RMU BYPASS	RESTORED/ REPAIRED	Part of : MAYAPURI INDUSTRIAL AREA PH-1	324	
32	16/10/2018	VKP	10:59	14:54	03:55	PLANNED SHUTDOWN	Grid:66 kV HASTSAL GRID To Feeder:11kV FDR C-BLOCK J.J COLONY , LT CIRCUIT-MAINTANCE WORK	RESTORED/ REPAIRED	Part of : C-BLOCK J.J COLONY HASTAL,, VIKAS PURI	514	
33	16/10/2018	JKP	10:58	15:47	04:49	PLANNED SHUTDOWN	Grid:33 kV MAYAPURI GRID To Feeder:11kV FDR POLICE CHOWKI HARI NGR , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : POLICE CHOWK HARI NAGAR	65	
34	16/10/2018	DWK	10:57	15:12	04:15	PLANNED SHUTDOWN	Grid:220kV PAPPAN KALAN 2 GRID To Feeder:11kV FDR P.P SECTOR-17 , 11kV FEEDER: TREE TRIMMING	RESTORED/ REPAIRED	Part of : PKT A,B&E DWARKA SECTOR 17,, HEALTH CENTER SEC-17 (HT CONSUMER), ABHINAV GLOBAL SCHOOL SEC 13	504	
35	16/10/2018	PJB	10:30	15:03	04:33	PLANNED SHUTDOWN	Grid:33 kV A - 4 PASCHIM VIHAR GRID To Feeder:11kV FDR A-4 CASH OFFICE , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : A-4 P/M PASCHIM VIHAR	61	
36	16/10/2018	NIF	10:15	15:51	05:36	PLANNED SHUTDOWN	Grid:66 kV I.O.C.BUWASAN GRID To Feeder:11kV FDR BAMNAULI , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : KANGENHERI,, BRIJWASAN,, JAI BHAGWAN VILLAGE KANGANHERI , VILLAGE DICHAON KALAN , GANGA RAM VILLAGE	497	
37	16/10/2018	NIF	10:15	15:45	05:30	PLANNED SHUTDOWN	Grid:66 kV DELHI ALI BOARD NAJAFGARH GRID To Feeder:11kV FDR SHYAM VIHAR , 11kV FEEDER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : VARDHMAN VIHAR,, VILLAGE DEENPUR,, VILL KANGENHERI, VILLAGE RADU SARAI,, VILLAGE REVYA KHANPUR	478	
38	16/10/2018	RKP	10:00	13:44	03:44	PLANNED SHUTDOWN	Grid:66 kV RIDGE VALLEY GRID To Feeder:11kV FDR MOTI BAGH , LT CIRCUIT: TREE TRIMMING	RESTORED/ REPAIRED	Part of : ANAND NIKETAN	77	
39	16/10/2018	NHP	10:00	15:51	05:51	PLANNED SHUTDOWN	Grid:33 kV OKHLA PHASE-2 GRID To Feeder:11kV FDR S/S NO-4, FEEDER-2 PHASE-2 , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : OKHLA PH-2	31	
40	16/10/2018	SKT	10:00	14:29	04:29	PLANNED SHUTDOWN	Grid:33 kV ADCHIN GRID To Feeder:11kV FDR LADO SARAI , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : LADO SARAI,, CHATARPUR VILLAGE,, CHATARPUR ENCLAVE	517	
41	16/10/2018	UMN	10:00	14:53	04:53	PLANNED SHUTDOWN	Grid:66 kV G - 3 P.P.X (BINDAPUR) GRID To Feeder:11kV FDR O-BLOCK UTTAM NAGAR , LT C&D-MAINTENANCE	RESTORED/ REPAIRED	Part of : O-BLOCK GEETA ENCLAVE,, BINDAPUR, M BLOCK UTTAM NAGAR	169	
42	16/10/2018	SKT	10:00	16:16	06:16	PLANNED SHUTDOWN	Grid:33 kV SHIVALKI GRID To Feeder:11kV FDR O/G TO COMP. CENTER MALVIYA NAGAR , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : GUPTA COLONY KHRIKI EXTN., PANCHSHEEL EXTN. MALVIYA NAGAR, PTS COLONY, NAVIYAN VIHAR	521	
43	16/10/2018	ALN	10:00	14:35	04:35	PLANNED SHUTDOWN	Grid:66 kV OKHLA PHASE -1 GRID To Feeder:11kV FDR O/G TO S/S NO-3 OKHLA PHASE-1 , TRANSFORMER-MAINTENANCE ACTIVITY	RESTORED/ REPAIRED	Part of : OKHLA PH-1,, GOVIND PURI GALI NO-10	29	
44	16/10/2018	VKI	14:30	15:45	01:15	EMERGENCY SHUTDOWN	Grid:33 kV ANDHERIA BAGH GRID To Feeder:11kV FDR O/G TO MANGALAPURI , 11kV FEEDER-PRREVENTIVE MAINTENANCE	RESTORED/ REPAIRED	Part of : GHITTORNI VILLAGE,, AYA NAGAR	427	
45	16/10/2018	NGL	11:58	13:51	01:53	EMERGENCY SHUTDOWN	Grid:66 kV NANGLOI GRID To Feeder:11kV FDR JWALA PURI CAMP NO.-4 , LT CIRCUIT-JUMPER REACTAMENT	RESTORED/ REPAIRED	Part of : B-BLOCK JWALA PURI CAMP NO-4	72	
46	16/10/2018	VKI	11:53	13:42	01:49	EMERGENCY SHUTDOWN	Grid:220kV VASANT KUNI TRANSO GR To Feeder:11kV FDR RANG PURI PAHARI , 11kV FEEDER-PRREVENTIVE MAINTENANCE	RESTORED/ REPAIRED	Part of : TARACHAND COLONY MAHIPALPUR,, RANG PURI PAHARI	497	
47	16/10/2018	MNG	10:18	11:53	01:34	EMERGENCY SHUTDOWN	Grid:66 kV G - 5 P.P.X (MATIALA) GRID To Feeder:11kV FDR C&D BLOCK MOHAN GARDEN , HVDS MAINTENANCE	RESTORED/ REPAIRED	Part of : B,C&D-BLOCK MOHAN GARDEN, A BLK MAHAVIR ENCLAVE, 80 YARD GRAM SHABA NAWADA	513	