

DISCOM : BYPL											
OUTAGE REPORT FOR:06:00 HRS. OF 17.10.2018 TO 06:00 HRS OF 18.10.2018											
Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Main Area affected	No. of consumer affected	Remarks
							Details				
1	17.10.2018	CCK	10:10	16:17	06:07	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	MAIN BAZAR-KHUSH DIL,HAUZ QAZI ROAD-PEEPAL MAHADEV GALI.	1521	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN P.S HAUZ QUAZI
2	17.10.2018	CCK	11:09	12:15	01:06	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	NAI SARAK-JOGIWARA,CHAWRI BAZAR-KHUSH,CHANDNI CHOWK.	5371	
3	17.10.2018	DGN	10:15	15:44	05:29	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	JHILMIL INDUSTRIAL AREA-JHILMIL COLONY.	90	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN PAPER PRODUCT:
4	17.10.2018	DGN	12:00	13:48	01:48	LT SYSTEM FEEDER PILLAR, TERMINATION, ETC.	PROJECT WORK	DISTRIBUTION BOX INSTALLED & LT STRAIGHT THROUGH JOINT MADE	TAHIRPUR VILLAGE.	40	
5	17.10.2018	DGN	13:00	16:25	03:25	LT SYSTEM FEEDER PILLAR, TERMINATION, ETC.	FIRE ON LT POLE	LT CABLE & SERVICE LINE DAMAGED DUE TO FIRE, SAME REPAIRED	BLOCK A-JHILMIL INDUSTRIAL AREA.	10	LT CABLE & SERVICE LINE DAMAGED DUE TO FIRE, SAME REPAIRED AT S/STN B-34 JHILMIL INDUSTRIAL AREA.
6	17.10.2018	DGN	14:54	16:19	01:24	LT FEEDER	TO ATTEND FAULT IN THE LINE	SERVICE LINE BROKEN, SAME REPAIRED	BLOCK G-MANSAROWAR PARK,	94	
7	17.10.2018	DRG	13:35	15:40	02:05	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	IP STATE-PRAGATI MAIDAN.	369	PREVENTIVE MAINTENANCE CARRIED OUT AT 11 KV FEEDER I.P.ESTATE_11kv_CB_I.P. STORM WATER PUMP HOUSE
8	17.10.2018	JLM	10:20	16:55	06:35	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	SUNDER PARK-SHAHDARA,BHOLA NATH NAGAR-SHAHDARA.	771	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN DALLAI MOHALLA:
9	17.10.2018	JLM	12:00	15:08	03:08	PLANNED SHUTDOWN	REPLACEMENT OF LT ACB	NEW LT ACB INSTALLED	ANAND VIHAR BLOCK A.	107	PROJECT WORK CARRIED OUT AT S/STN ANAND VIHAR A BLK
10	17.10.2018	KRN	10:22	15:56	05:34	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK 13-GEETA COLONY,BLOCK E-JAGATPURI.	2328	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN GANESH PARK
11	17.10.2018	KRN	10:50	15:32	04:42	PLANNED SHUTDOWN	PROJECT WORK	DT CLEANING WORK CARRIED OUT	BLOCK 9-GANDHI NAGAR,BLOCK 9-RAGHUBARPURA.	844	PROJECT WORK CARRIED OUT AT S/STN KOTHI BHAGWAN DAS OUTSIDE
12	17.10.2018	KRN	11:42	13:25	01:43	PLANNED SHUTDOWN	PROJECT WORK	DISTRIBUTION BOX REPAIRED	BLOCK B-JAGATPURI,KRISHNA NGR.	4199	
13	17.10.2018	KWN	10:00	16:55	06:55	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK A-HARIJAN BASTI,BLOCK A-RAMA GARDEN.	867	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN COMPLAINT CENTER KARAWAL NAGAR
14	17.10.2018	KWN	10:00	15:58	05:58	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	NON COMM AREA-DAYALPUR EXTN.	173	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN VILL.SADAT PUR DP (HVDS)
15	17.10.2018	KWN	12:18	15:16	02:57	HVDS CABLE & OTHER SYSTEM	TO ATTEND FAULT IN THE LINE	3-PHASE HVDS LEAD FOUND FAULTY, SAME REPAIRED	BLOCK-A PH-10 SHIV VIHAR.	885	3-PHASE HVDS LEAD FOUND FAULTY, SAME REPAIRED AT BLOCK-A PH-10 SHIV VIHAR
16	17.10.2018	LNR	10:15	16:45	06:30	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK F-VISHWAKARMA PARK.	173	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN ANAR MASJID
17	17.10.2018	LNR	10:23	16:26	06:03	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK A,D-PREET VIHAR.	442	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN MADHUBAN
18	17.10.2018	LNR	11:12	12:14	01:02	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	PATPAR GANJ INDUSTRIAL AREA,BHARAT GAS-GAZIPUR VILLAGE.	344	
19	17.10.2018	NNG	10:12	16:05	05:53	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK D-HARSH VIHAR,BLOCK C-SEWA DHAM.	173	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN KARDAM PURI EXT S/S (AZAD CHOWK)

20	17.10.2018	NNG	10:15	16:25	06:10	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	KACHHI KARDAM PURI,NAND NAGRI.	173	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN D- BLOCK HARSH VIHAR(HVDS)
21	17.10.2018	PHG	10:00	16:36	06:36	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK T-AHATA KEDARA,SADAR BAZAR - RAM NAGAR.	1284	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN NEW QASAB PURA
22	17.10.2018	PHG	11:30	13:20	01:50	PLANNED SHUTDOWN	REPLACEMENT OF LT ACB	BURNT LTACB REPLACED BY NEW ONE.	BLOCK III-ARAM BAGH,CHUNA MANDI-PAHAR GANJ.	388	
23	17.10.2018	SRD	10:00	12:24	02:24	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK 12A-KAROL BAGH,BLOCK_1A-REHAGAR PURA.	951	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN 21 WEA K.BAGH TIKONA PARK
24	17.10.2018	SRD	10:30	15:57	05:27	PLANNED SHUTDOWN	PROJECT WORK	NEW LTAB LAID TO IMPROVE THE NETWORK	BLOCK_47-BEADON PURA.	871	PROJECT WORK CARRIED OUT AT S/STN H.S.ROAD BASEMENT (MCD OFFICE)
25	17.10.2018	SRD	10:30	15:56	05:26	PLANNED SHUTDOWN	PROJECT WORK	NEW LTAB LAID TO IMPROVE THE NETWORK	BLOCK 29-NAIWALA,BLOCK A-JHANDEWALAN.	251	PROJECT WORK CARRIED OUT AT S/STN TIBBIA COLLEGE
26	17.10.2018	SRD	10:30	14:10	03:40	PLANNED SHUTDOWN	PROJECT WORK	DISTRIBUTION BOX REPLACED	BLOCK 8, 16-OLD RAJENDRA NAGAR.	534	PROJECT WORK CARRIED OUT AT S/STN SETHI S/STN OLD(PETROL PUMP)RAJEN
27	17.10.2018	SRD	10:30	15:56	05:26	PLANNED SHUTDOWN	PROJECT WORK	OVERHEAD CONDUCTOR REPLACED BY LTAB TO IMPROVE THE NETWORK	BLOCK_1A-REHAGAR PURA,BLOCK_2A-SAT NAGAR.	1008	PROJECT WORK CARRIED OUT AT S/STN R.K.DAS NO-2:
28	17.10.2018	VSE	10:25	17:21	06:56	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK A-NEW ASHOK NAGAR.	940	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN A-BLK NEW ASHOK NAGAR
29	17.10.2018	VSE	10:25	13:33	03:08	PLANNED SHUTDOWN	PROJECT WORK	NETWORK UPGRADATION CARRIED OUT	BLOCK B-MAYUR VIHAR PHASE III.	1041	PROJECT WORK CARRIED OUT AT S/STN STN 4 GHAROLI DAIRY CL MVR PH-3:
30	17.10.2018	YVR	10:10	17:00	06:50	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK B-MANUJPUR,BLOCK C-BHAJANPURA,GAMRI-GHONDA.	173	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN B BLOCK BHAJANPURA-11
31	17.10.2018	YVR	10:10	12:13	02:03	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK E-NEW SEELAMPUR PHASE II.	13	PREVENTIVE MAINTENANCE CARRIED OUT AT S/STN E BLOCK SEELAMPUR
32	17.10.2018	YVR	11:45	14:38	02:53	PLANNED SHUTDOWN	PREVENTIVE MAINTENANCE WORK	PREVENTIVE MAINTENANCE CARRIED OUT	BLOCK B-MANUJPUR,BLOCK B-GARI MANDU,BLOCK C-BHAJANPURA.	8525	PREVENTIVE MAINTENANCE CARRIED OUT AT 11 KV FEEDER 220KV SOUTH OF WAZIRABAD GRID_11kv_CB_B-BLK.BHAJANPURA
33	17.10.2018	YVR	12:39	16:50	04:11	PLANNED SHUTDOWN	PROJECT WORK	LOAD BALANCING CARRIED OUT IN TRANSFORMERS	GHONDA PATTI CHAUHAN,ARVIND NAGAR-GHONDA.	1225	PROJECT WORK CARRIED OUT AT S/STN PRIMARY SCHOOL GAUTAM VIHAR: