

DISCOM : ____TATA Power-DDL____

OUTAGE REPORT FOR : ____16-10-2018____

Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Main Area affected	No. of consumer affected	Remarks
						Main Reason	Details				
1	16-Oct-2018	Narela	08:10	09:15	01:05	HT SYSTEM FAULT	HT Jumper Sparking	Restored/Repaired	Parts of : Khampur	4445	Interruption due to fault
2	16-Oct-2018	Shalimar Bagh	09:42	11:33	01:51	LT FEEDER	LT ABC Burnt	Restored/Repaired	Parts of : Baba Colony	473	Interruption due to fault
3	16-Oct-2018	Moti Nagar	11:25	12:39	01:14	DISTRIBUTION TR.	Cat Electrocuton on DT	Restored/Repaired	Parts of : Basai Darapur	393	Interruption due to fault
4	16-Oct-2018	Shalimar Bagh	11:48	13:45	01:57	LT FEEDER	LT Cable Faulty	Restored/Repaired	Parts of : I.P. Colony	375	Interruption due to fault
5	16-Oct-2018	Civil Lines	11:50	13:04	01:14	HVDS CABLE & OTHER SYSTEM	HT ABC Sparking	Restored/Repaired	Parts of : Vijay Nagar	594	Interruption due to fault
6	16-Oct-2018	Model Town	15:04	17:31	02:27	FORCE MAJEURE (RAIN/WATER LOGGING/STORM, ETC.)	Tree Branch Fell on Line	Restored/Repaired	Parts of : Indra Vihar	323	Force majeure due to sabotage
7	16-Oct-2018	Bawana	15:49	17:50	02:01	FORCE MAJEURE (RAIN/WATER LOGGING/STORM, ETC.)	External Item Fell on Line	Restored/Repaired	Parts of : Punjab Khor	1670	Force majeure due to sabotage
8	16-Oct-2018	Mangolpuri	15:55	17:18	01:23	DISTRIBUTION TR.	DD Jumper Burnt	Restored/Repaired	Parts of : Budh Vihar	2458	Interruption due to fault
9	16-Oct-2018	Civil Lines	16:16	17:51	01:35	LT FEEDER	LT Jumper Sparking	Restored/Repaired	Parts of : Roop Nagar	374	Interruption due to fault
10	16-Oct-2018	Bawana	16:06	17:45	01:39	DISTRIBUTION TR.	DD Jumper Burnt	Restored/Repaired	Parts of : Karala Village	1323	Interruption due to fault
11	16-Oct-2018	Mangolpuri	17:42	18:53	01:11	DAMAGE BY OTHER AGENCIES	HT Pole Damaged by Unknown Vehicle	Restored/Repaired	Parts of : Laxmi Vihar	3187	Force majeure due to sabotage
12	16-Oct-2018	Shalimar Bagh	18:50	20:33	01:43	LT SYSTEM FEEDER PILLAR, TERMINATION, ETC.	Tyco Box Burnt	Restored/Repaired	Parts of : Sangam Vihar	415	Interruption due to fault
13	16-Oct-2018	Mangolpuri	10:58	13:46	02:48	PLANNED SHUTDOWN	HT Line Extension	Restored/Repaired	Parts of : T-Block Mangolpuri	521	Planned outage
14	16-Oct-2018	Model Town	10:03	13:52	03:49	PLANNED SHUTDOWN	HT ABC Replacement	Restored/Repaired	Parts of : Mukherjee Nagar	452	Planned outage
15	16-Oct-2018	Model Town	10:42	14:10	03:28	PLANNED SHUTDOWN	DT Augmentation	Restored/Repaired	Parts of : Azadpur	465	Planned outage
16	16-Oct-2018	Shalimar Bagh	11:14	13:23	02:09	PLANNED SHUTDOWN	DT Oil Top-up	Restored/Repaired	Parts of : Mahendra Park	1853	Planned outage
17	16-Oct-2018	Shalimar Bagh	10:10	16:20	06:10	PLANNED SHUTDOWN	HT ABC Replacement	Restored/Repaired	Parts of : Jahangirpuri	1950	Planned outage
18	16-Oct-2018	Keshav Puram	10:10	12:26	02:16	PLANNED SHUTDOWN	New HT Pole Erection	Restored/Repaired	Parts of : Ashok Vihar	379	Planned outage

Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Main Area affected	No. of consumer affected	Remarks
						Main Reason	Details				
19	16-Oct-2018	Bawana	10:54	16:50	05:56	PLANNED SHUTDOWN	New DT Installation	Restored/Repaired	Parts of : Ladpur	1514	Planned outage
20	16-Oct-2018	Narela	10:51	14:13	03:22	PLANNED SHUTDOWN	Project Work	Restored/Repaired	Parts of : Singhu Village	760	Planned outage
21	16-Oct-2018	Narela	12:17	16:02	03:45	PLANNED SHUTDOWN	New HT Pole Erection	Restored/Repaired	Parts of : Ghogha Village	2822	Planned outage
22	16-Oct-2018	Shalimar Bagh	10:37	11:45	01:08	PLANNED SHUTDOWN	DT Oil Top-up	Restored/Repaired	Parts of : Bhalswa	849	Planned outage
23	16-Oct-2018	Bawana	12:09	13:25	01:16	PLANNED SHUTDOWN	Tree Trimming	Restored/Repaired	Parts of : Qutubgarh	1633	Planned outage
24	16-Oct-2018	Narela	13:19	17:14	03:55	PLANNED SHUTDOWN	General Maintenance	Restored/Repaired	Parts of : Bakhtawarpur	591	Planned outage

Sr. No.	Date	Division	Start Time	End Time	Duration	Reason for Outage		Action	Main Area affected	No. of consumer affected	Remarks
						Main Reason	Details				